DIVISION 07 – THERMAL AND MOISTURE PROTECTION 07 10 00 DAMPPROOFING AND WATER PROOFING

PART 1 - GENERAL

1.01 SUMMARY

A. Scope:

- 1. Acceptable forms of exterior waterproofing and dampproofing include sheet, fluid-applied, and bentonite waterproofing (see section 07 17 00, Bentonite Waterproofing).
- Exterior walls below grade are to be thoroughly waterproofed with a rubberized membrane. Consultant is responsible for verifying site-specific hydrostatic head requirements based on geotechnical survey during design.
- 3. Shower rooms and drying rooms over habitable spaces shall have a membrane waterproofing pan with cemented joints, per the Ceramic Tile Institute's recommendation. This material shall cover the total floor area and be turned up all walls a minimum of 8 inches.
- 4. Floors with drains shall be sloped to drain into floor drains, and shall slope away from doors to adjoining spaces.
- 5. Mechanical rooms and kitchens over habitable spaces shall have waterproofing applied to protect the space below. Pipe and conduit penetrations through the floor are to be sleeved with lips projecting 1-1/2 inches to prevent drainage through the holes.

1.02 QUALITY ASSURANCE

A. Single Source Responsibility: Obtain primary dampproofing materials and primers from one source and by a single manufacturer. Provide secondary materials only as recommended by manufacturer of primary materials.

PART 2 - PRODUCTS

2.01 PRE-APPROVED MANUFACTURERS

- A. Sheet:
 - 1. BF Goodrich
 - 2. Carlisle
- B. Bentonite: See section 07 17 00 (Bentonite Waterproofing)
- 2.02 WARRANTY

DIVISION 07 – THERMAL AND MOISTURE PROTECTION 07 10 00 DAMPPROOFING AND WATER PROOFING

A. Provide written warranties against defective materials and workmanship for a period of at least ten years following date of substantial completion.

PART 3 - EXECUTION (NOT USED)

END OF SECTION