

# **DIVISION 07 – THERMAL AND MOISTURE PROTECTION**

## **07 60 00 FLASHING AND SHEET METAL**

### **PART 1 - GENERAL**

#### 1.01 METAL FLASHING

- A. Flashing shall be 24 gauge galvanized sheet metal or an equal thickness of aluminum.

#### 1.02 SYSTEM REQUIREMENTS

- A. Full cap flashing is required where exterior building walls terminate in a parapet.
- B. Flashing is required under unit masonry copings.

#### 1.03 QUALITY ASSURANCE

- A. Wind Uplift Resistance: Provide roof assemblies that meet requirements of Underwriters Laboratories (UL) 580 for Class 90 wind uplift resistance (design for minimum 100 mph winds).
  - 1. Maintain current UL equipment certification for field-rolled panel forming equipment.

### **PART 2 - PRODUCTS (NOT USED)**

### **PART 3 - EXECUTION (NOT USED)**

**END OF SECTION**