

DIVISION 08 – OPENINGS

08 10 00 DOORS AND FRAMES

PART 1 - GENERAL

1.01 REQUIREMENTS

- A. Use standard door sizes and standard frame design to avoid complications when remodeling occurs. Standard size: 3 foot-0 inch x 7 foot-0 inch x 1-3/4 inches subject to code compliance.
- B. In general, use metal door frames throughout. Proposed exceptions must be approved by the WSU Project Manager.
- C. All paired doors which must lock or latch shall have a keyed removable center mullion post.
- D. Doors that open into heavy traffic public areas shall be equipped with relites.
- E. Provide kickplates where appropriate.

1.02 RESTRICTIONS

- A. Vertical strikes and rod assemblies are not acceptable at Washington State University.
- B. Factory-made door-frame combination systems are not acceptable at Washington State University.
- C. No door materials shall contain asbestos in any quantity or any form.

1.03 OTHER REQUIREMENTS

- A. When replacing doors is required during facility renovations, replace both doors and frames as a paired assembly. Individual reuse of either doors or frames after removal requires approval of the WSU Construction Manager.

PART 2 - PRODUCTS

2.01 METAL STOREFRONT GLAZING/ENTRANCE SYSTEMS

- A. Preferred Manufacturer: Kawneer. Proposed alternatives require approval from WSU Construction Services.

PART 3 - EXECUTION (NOT USED)

END OF SECTION