

DIVISION 09 – FINISHES

09 21 00 PLASTER AND GYPSUM BOARD ASSEMBLIES

PART 1 - GENERAL

1.01 CEMENT PLASTER, LIGHTWEIGHT PLASTER, ACOUSTICAL PLASTER

- A. Do not use without specific approval of the WSU Facilities Services Project Manager.

1.02 INTERIOR GYPSUM WALLS, SOFFITS, AND CEILINGS

- A. In general, interior corridor and common area walls shall have a “smooth wall” finish that meets or exceeds Gypsum Council Level 4 Gypsum board finish.
- B. Service areas (Custodial Spaces, Mechanical Rooms, Maintenance Mechanic Rooms, etc.) shall meet or exceed Gypsum Council Level 2 Gypsum board finish.

1.03 FINISH

- A. Two separate coats of joint compound shall be applied over all flat joints and one separate coat of joint compound shall be applied over interior angles. Fastener heads and accessories shall be covered with three separate coats of joint compound. All joint compound shall be smooth and free of tool marks and ridges.

1.04 DETAIL

- A. Do not run wall finish (plaster or gypsum board) around stair treads and risers.
- B. All unpainted surfaces shall be primed with an appropriate latex primer rated for new gypsum construction applied within manufacturer’s instructions and specifications.

1.05 PROTECTION OF INTERIOR SURFACES

- A. Corner Guards: Provide metal corner guards in high-traffic areas and public spaces. See details in section 05 50 00 Metal Fabrications.
- B. Areas subject to regular abuse or requiring frequent cleaning (i.e., recycling containers, drinking fountains, mop sinks, etc.) shall be protected with fiberglass-reinforced plastic (FRP), plastic laminate, or approved equivalent. Specific locations for wall protection shall be submitted for approval by the WSU Project Manager.

DIVISION 09 – FINISHES
09 21 00 PLASTER AND GYPSUM BOARD ASSEMBLIES

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION