

DIVISION 09 – FINISHES

09 30 00 TILING

PART 1 - GENERAL

1.01 SCOPE

- A. Ceramic tile is the required finish for floors and wainscot in all restrooms, locker rooms and showers. Epoxy grout is required.

1.02 LOCATIONS

- A. Walls behind lavatories and urinals shall be ceramic tile.
- B. Toilet rooms shall have floor and base of ceramic tile.
- C. Shower rooms shall have floors, walls and ceilings of ceramic tile.

1.03 CONSTRUCTION

- A. Tile floors shall slope $\frac{1}{4}$ " per foot toward the floor drain.
- B. All unsealed ceramic tile shall be sealed with a penetrating sealer if recommended by the tile manufacturer.
- C. Underlayments or setting products such as waterproofing and/or crack isolation shall be used in all areas that need protection.
- D. Grout installation:
 - 1. Wet areas (restrooms, shower rooms etc.): Use epoxy grout.
 - 2. Common areas (corridors, entries, lobbies etc.): Stain-resistant grout with polyurethane copolymer is acceptable.
 - i. Acceptable manufacturers:
 - 1) Laticrete Spectralock
 - 2) Flextile Colourmax Plus.
 - 3. Sanded grout is not acceptable.
 - 4. Grout color must be approved by WSU Facilities Services Interior Design.
 - 5. All floor tiles shall receive a sealer recommended by tile and grout manufacturer.

1.04 MAINTENANCE

DIVISION 09 – FINISHES
09 30 00 TILING

- A. At project conclusion, provide replacement tile of every color and shape used at the rate of 5 percent of the installed area. Deliver to WSU Construction Manager.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (NOT USED)

END OF SECTION