

# **DIVISION 22 - PLUMBING**

## **22 00 00 PLUMBING**

### **PART 1 - GENERAL**

#### 1.01 SCOPE:

- A. This section applies to all plumbing and piping systems inside buildings or interfacing within five feet of buildings. The detailed requirements of Plumbing Pumps (22 06 10 13), Steam and Condensate (23 22 00), Central Chilled Water (33 60 00), and Deionized Water (40 23 13) are addressed in separate sections.
- B. As part of the design process (no later than the 50% Construction Drawings), the Consultant shall submit a Process and Instrumentation Drawing (P&ID) for each major system, illustrating all subcomponents of that system, for review by the WSU Project Manager and Engineering Services.
  - 1. For renovation and renewal projects, the Process and Instrumentation Drawing (P&ID) shall illustrate all subcomponents of the existing systems, together with the connections and integration of all new work.

#### 1.02 DESIGN REQUIREMENTS

- A. Coordinate plumbing runs with Mechanical and Electrical systems to maintain grade without offsets.
- B. Install each run with the minimum necessary joints and couplings, but with adequate and readily accessible unions for disassembly, maintenance, or replacement of valves and equipment.
- C. Provide drain valves at main shut-off valves, low points of piping, and apparatus.
- D. All equipment, fixtures, and appliances shall be installed where readily accessible for maintenance, removal, and replacement.
  - 1. Install valves at each piece of equipment, fixture, or appliance so that the supply and return services can be shut off to remove the item without draining the system.
- E. Install valves for proper isolation of piping and equipment, including valves in branch lines to isolate sections of piping.
- F. Valves shall be installed where readily accessible.

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

#### **PART 2 - PRODUCTS**

##### 2.01 WATER PIPING, BURIED WITHIN 5 FEET OF BUILDING

- A. Copper Tubing:
  - 1. Copper Tubing: Type K, hard drawn.
  - 2. Fittings: Wrought copper.
- B. Galvanized steel pipe with malleable fittings
- C. Joints (both copper tubing and galvanized steel):
  - 1. Mechanical
  - 2. Double wrap 20 mil polyethylene tape

##### 2.02 WATER PIPING, ABOVE GRADE

- A. Copper Tubing: Type L, hard drawn.
- B. Fittings:
  - 1. Cast brass
  - 2. Wrought copper
- C. Joints:
  - 1. Solder
  - 2. B cup Silver Braze
  - 3. Lead Free
- D. Substitutions must be approved by WSU Engineering Services. The following substitutions are generally acceptable:
  - 1. Press Fit
  - 2. Propress
  - 3. PEX tubing and fittings:
    - i. Pressure/temperature rating 160 psi at 73°F.
    - ii. Pressure/temperature rating at 100 psi at 180°F.

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

- iii. Pressure/temperature rating at 80 psi at 200°F.
- iv. NSF-pw
- v. Shall comply with the most current and adopted versions of ASTM F876, F877, F1807, F2159, and F2023.
- vi. Shall comply with the most current and adopted version of CSAB137.5.
- vii. Shall be certified by UPC.
- viii. SDR-9
- ix. Size ranges ½ inch to 1 inch.

#### **2.03 SANITARY SEWER PIPING, BURIED WITHIN 5 FEET OF BUILDING**

- A. Cast Iron: Service weight soil pipe with no-hub couplings. No-hub couplings shall be Husky 6000 with stainless steel multiple band clamps, or equivalent.
  - 1. Tyler cast iron soil pipe is not acceptable. This product has a history of poor performance on the WSU campus.

#### **2.04 SANITARY SEWER PIPING, BUILDING INTERIOR**

- A. Cast Iron: Service weight soil pipe with no-hub couplings.
  - 1. No-hub couplings shall be Husky 6000 with stainless steel multiple band clamps, or equivalent.
  - 2. Tyler cast iron sanitary pipe is not acceptable. This product has a history of poor performance on the WSU campus.
- B. PVC:
  - 1. Cleanouts: Require cast iron pipe and fittings (including a brass plug) to the first piping change in direction for protection during cleaning.
- C. ABS (solid core)
  - 1. Cleanouts: Require cast iron pipe and fittings (including a brass plug) to the first piping change in direction for protection during cleaning.
- D. A shielded transition coupling shall be required when joining dissimilar piping materials (i.e., PVC to cast iron transitions).
  - 1. Pre-approved Manufacturer:
    - i. ProFlex

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

#### 2.05 SANITARY SEWER VENT LINES

- A. Cast iron: Service weight cast iron soil pipe
- B. ABS (solid core)

#### 2.06 LABORATORY WASTE & VENT:

- A. Rigid polypropylene with mechanical joints (above grade)
  - 1. Fused polypropylene joints may be used where it can be demonstrated the joints are accessible for maintenance personnel and equipment. Use of these alternates must be approved by WSU Engineering Services.
  - 2. Underslab use of polypropylene may be considered acceptable; must be approved by WSU Engineering Services.
- B. CPVC (manufacturer's designated products for Lab Waste only)
- C. Orion
- D. Aquatherm
- E. Duriron

#### 2.07 DISTILLED / DEMINERALIZED WATER PIPING

- A. Piping: Schedule 80 PVC
- B. Fittings: Schedule 80 PVC

#### 2.08 HYDRONIC PIPING

- A. Schedule 40 black steel (mechanical joint fittings acceptable)
- B. Type "L" hard drawn copper tube
- C. Aquatherm
- D. PEX (use of PEX must be specifically approved by WSU Engineering Services)

#### 2.09 INSULATION

- A. Piping systems requiring insulation are:
  - 1. Steam (see 23 22 00)
  - 2. Condensate (see 23 22 00)

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

3. Domestic cold water
  4. Domestic hot water
  5. Domestic hot water return lines
  6. Hydronic piping
  7. Interior down spouts
  8. Chilled water (see 33 60 00)
  9. Refrigeration (see 23 61 00)
  10. Heat recovery
- B. Serviceable fittings for all the piping systems listed above shall require removable insulation jackets with Velcro ties, regardless of WA State Energy code requirements.
- C. Piping and equipment subject to condensation shall be insulated and have support systems allowing full insulation thickness.
- D. Domestic hot and cold water lines and rainwater piping shall be insulated with WAC 51-11 compliant fiberglass with vapor barrier, thickness compliant with the latest Washington State Energy Code.
- #### 2.10 NATURAL GAS PIPING, ABOVE GRADE
- A. Steel Pipe:
1. Schedule 40 black steel
  2. Fittings:
    - i. Malleable iron
    - ii. Forged steel welding type
  3. Interior valves to be WOG rated 150 psi.
  4. Exterior valves must be greased or lubricated.
  5. Joints: Screwed for pipe two inches and under
  6. Buried gas lines downstream of the gas meter are not acceptable. All buried gas lines shall be the property and under control of Avista Utilities.

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

#### 2.11 VACUUM PIPING

- A. Schedule 40 steel pipe
- B. Type "L" hard drawn copper tube
  - 1. Soldered joints
  - 2. ProPress System
- C. PEX (manufacturer's designated products for Vacuum Piping only)

#### 2.12 COMPRESSED AIR PIPING

- A. Schedule 40 steel pipe
- B. Type "L" hard drawn copper tube
  - 1. Brazed joints
  - 2. ProPress System
- C. PEX (manufacturer's designated products for Compressed Air Piping only)

#### 2.13 FLANGES, UNIONS, AND COUPLINGS

- A. Pipe Size 2 Inches and under:
  - 1. 250 psig malleable iron unions for threaded ferrous piping
  - 2. Bronze unions for copper pipe
- B. Pipe Size over 2 Inches:
  - 1. 250 psig forged steel slip-on flanges for ferrous piping
  - 2. Bronze flanges for copper piping
  - 3. Neoprene gaskets for gas service; 1/16 inch thick preformed neoprene
- C. Dielectric Connections:
  - 1. Use brass unions and brass nipples. Dielectric unions are not acceptable.

#### 2.14 GATE VALVES

- A. Specifications:

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

1. Up to 2 Inches: Bronze body, non-rising stem and hand wheel, inside screw, single wedge or disc, threaded ends, 150 lb. body rating.
2. Over 2 Inches: Iron body, bronze trim, non-rising stem and hand wheel, flanged ends, 150 lb. body rating.

#### **B. Acceptable Manufacturers:**

1. Nibco
2. Kennedy
3. Milwaukee
4. Vennessa
5. Tyco

### **2.15 GLOBE VALVES**

#### **A. Specifications:**

1. Up to 2 Inches: Bronze body, rising stem and hand wheel, inside screw, renewable composition disc, threaded ends, with back seating capacity, 600 lb. body rating.
2. Over 2 Inches: Iron body, bronze trim, rising stem and hand wheel, OS&Y, plug- type disc, flanged ends, renewable seat & disc.

#### **B. Acceptable Manufacturers:**

1. Nibco
2. Kennedy
3. Milwaukee
4. Vennessa
5. Tyco

### **2.16 BALL VALVES**

#### **A. Specifications:**

1. Up to 2½ Inches: Bronze body, stainless steel ball; Teflon seats and stuffing box ring; lever handle and balancing stops; threaded ends with union; 150 lb. body rating.

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

2. 3 Inches or greater: Cast steel body, chrome plated steel ball; Teflon seat and stuffing box seals; lever handle or gear drive hand wheel; flanged; 150 lb. body rating (or greater, as required by system pressure).
- B. Acceptable Manufacturers:
1. Nibco
  2. Jenkins
  3. Kennedy
  4. Powell
  5. Ohio
  6. Milwaukee

#### 2.17 BUTTERFLY VALVES

- A. Butterfly Valves are not acceptable on the WSU domestic water system. Use Gate Valves or Ball Valves for isolation points.

#### 2.18 SWING CHECK VALVES

- A. Specifications:
1. Up to 1 Inch:
    - i. Bronze 45 degree swing disc
    - ii. Solder ends
  2. Over 1 Inch:
    - i. Iron body
    - ii. Bronze trim
    - iii. 45 degree swing disc
    - iv. Renewable disc and Teflon seat
    - v. Flanged ends
- B. Acceptable Manufacturers:
1. Febco



## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

2. Kennedy
3. Stockham
4. Watts
5. Powell
6. Crane
7. Ohio

#### **2.19 SILENT CHECK VALVES**

A. Required where pressure gradient must be maintained during shutoff (i.e., downstream of pumps).

1. Silent checks shall not be used on steam lines downstream of traps.

B. Specifications:

1. Up to 2 Inches: Bronze body, 200 psi @ 250° F, threaded ends, resilient seats, center guided disk.
2. Over 2 Inches: Iron body, bronze or stainless steel trim, class 125, 316 stainless steel spring, dual plate or tilting-disk type, resilient seat.

C. Acceptable Manufacturers:

1. Metra-Flex
2. Cla-Val
3. GA Industries
4. Nibco
5. Pentair
6. Victaulic (for grooved pipe systems)

#### **2.20 RELIEF VALVES**

A. Specifications:

1. Bronze body
2. Teflon seat

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

3. Steel stem and springs
4. Automatic
5. Direct pressure actuated
6. Capacities ASME certified and labeled

#### **B. Acceptable Manufacturers:**

1. Grinnell, Bell & Gossett
2. Taco
3. Crane
4. Watts

#### **2.21 GRISWOLD VALVES**

- A. Typically specified in the 1-14 psi range.
- B. Soldered connections are not acceptable; integral threaded unions are required on both sides.

#### **2.22 EXPANSION TANKS**

- A. Where expansion tanks are required on domestic water systems, specify diaphragm expansion tanks.

#### **2.23 METERS AND INSTRUMENTATION**

##### **A. Water Meters:**

###### **1. Pre-Approved Manufacturers/Models:**

- i. Siemens SITRANS FUS1010 clamp-on ultrasonic flowmeter
- ii. ONICON F-3100 series electromagnetic in-line flowmeter

##### **B. Thermometers:**

1. Provide thermometers where equipment causes fluid temperature changes (except for finned radiation and convectors).
2. Thermometers shall be installed in wells so that they can also be removed from the system and replaced without shutting the system down.

##### **C. Pressure Gauges:**

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

1. Provide pressure gauges for all pumps (suction and discharge). Also see section 22 06 10 13 (Plumbing Pumps).
2. Install a single water-filled pressure gauge with isolation valves across both supply and return lines to compare system pressure.
3. Gauge selection shall typically center on design operating pressure and cover safe system operating range without damage.
4. Provide isolation valves on both sides of gauges.
5. Provide a throttle valve for each gauge to allow snubbing and isolation function.
6. All gauges shall be installed where easily accessible and legible for Maintenance and Utilities personnel.

#### **2.24 SPECIAL REQUIREMENTS**

##### **A. Mechanical Rooms:**

1. Above-ground mechanical room floor openings require curbs.
2. Floor penetrations (piping, conduit, etc.) require pipe sleeves 2 inches above floor.

##### **B. Floor drains: Floor drains are required in all mechanical rooms, elevator pits, baths, toilet rooms, kitchens, laundry rooms, shower drying areas, and service sink closets in addition to wet labs and for other building program needs.**

1. Floor drains with potential for solids need to have basket strainers.
2. Large capacity floor sinks or drains are preferable to trench drains in all cases.
3. PVC or other plastic fixtures are not acceptable in any applications.
4. Duriron or cast iron need to be protected with a factory-applied corrosion-resistant coating.

##### **C. Water Fountains**

1. WSU has generally standardized upon filtered water cooler and bottle-filling stations. Variations require approval from WSU Engineering Services.

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

2. Pre-Approved Products: Elkay Filtered EZH2O Bottle Filling Station with Single ADA Cooler

#### **D. Grease Traps**

1. Grease traps shall only be installed where specifically required by the end user or by code. Grease trap design and installation requires approval from WSU Engineering Services. Maintenance and renewal of grease traps shall be an end user responsibility.
2. Specifications:
  - i. Fabricated steel with acid-resistant coating inside and outside
  - ii. Flow control fitting
  - iii. Removable baffles
  - iv. Threaded inlet and outlet
  - v. Internal air relief
  - vi. Double-wall trap without cleanout and gasket scoriated cover
3. Acceptable Manufacturers:
  - i. Wade
  - ii. Zurn
  - iii. Josam
  - iv. J.R. Smith

#### **E. Solids Separation and Collection**

1. Facilities and applications with large quantities of biodegradable waste shall be collected and composted at the WSU Compost Facility, with appropriate collection methods to prevent disposal in Sanitary Sewer.
2. Sink-mounted garbage disposals are not acceptable at WSU.

## **PART 3 - EXECUTION**

### **3.01 CONNECTION**

- A. Any connection to the WSU domestic water system – including temporary construction connections – shall require approval and observation by the

## **DIVISION 22 - PLUMBING**

### **22 00 00 PLUMBING**

WSU Cross-Connection Control Specialist. Coordinate through the WSU Construction Manager.

#### **3.01 DISINFECTION**

- A. New or repaired public drinking water systems shall be disinfected prior to connection, in accordance with the standards of the most current Uniform Plumbing Code as modified by Chapter 51-56 WAC, and in accordance with the most current version of ANSI/AWWA C651, "Disinfecting Water Mains."
- B. For installation of new lines and systems, the Contractor is responsible to ensure all chlorination is performed according to the most current version of ANSI/AWWA C651, and that adequate bacteriological sampling results are obtained from a WA State approved laboratory. Submit written documentation of chlorination and bacteriological sampling to the WSU Construction Manager, for review and approval by WSU EH&S and the Water Distribution Manager, prior to placing new lines in service.

#### **3.02 TESTING**

- A. Conduct pressure testing in accordance with the manufacturer's recommendations. Contractor shall submit proposed pipe testing procedures to the WSU Construction Manager for review and approval by WSU Engineering Services.
- B. No testing water or chlorinated water may be discharged into the sanitary or storm sewer system in accordance with the most current and adopted version of Washington Administrative Code (WAC) 173-201A. All chlorinated water shall either be treated to remove chlorine prior to discharge into sewers, or discharged into an area which does not impact storm drains or surface waters. If soil is the only contaminant, the wastewater may be discharged into the storm sewer catch basins provided they are protected using Best Management Practices (BMPs), per the requirements of WSU section 33 40 00 (Storm Drainage Utilities).
- C. The Contractor shall notify the WSU Construction Manager in writing 48 hours prior to testing. The Contractor shall make all necessary testing and sampling arrangements, making all necessary arrangements with the WA State approved testing laboratory. The Construction Manager shall notify the following as to date and time of flushing and hydrostatic and bacteriological testing:
  - 1. WSU Water Distribution Manager
  - 2. WSU Environmental Health and Safety
  - 3. WSU Fire Department

**DIVISION 22 - PLUMBING**  
**22 00 00 PLUMBING**

**END OF SECTION**