

**DIVISION 22 – PLUMBING**  
**22 05 00 COMMON WORK RESULTS FOR PLUMBING**  
**22 05 29 HANGERS AND SUPPORTS FOR PLUMBING PIPING AND**  
**EQUIPMENT**

**PART 1 - GENERAL**

1.01 PIPE HANGARS AND RESTRAINTS

- A. Pipe earthquake restraints shall be designed in accordance with the current USGS Seismic Zone for the each particular WSU campus location.
- B. Pipes above suspended ceilings shall still be accessible and at sufficient distance from tile so that the ceiling tiles can be readily removed and replaced for maintenance functions without damaging them.
- C. Perforated tape hangers are prohibited.

**PART 2 - PRODUCTS (NOT USED)**

**PART 3 - EXECUTION (NOT USED)**

**END OF SECTION**