



**NOTES**

- 1) COORDINATE THERMOSTAT CONTACTS AND CONTACTOR COIL VOLTAGE; OK TO USE UNSWITCHED HEATING CABLE BRANCH CIRCUIT. SET THERMOSTAT TO SWITCH 'ON' BELOW 40° F.
- 2) OKAY TO OMIT CONTACTOR FOR SINGLE CIRCUIT APPLICATION.
- 3) CONTACT WSU ENGINEERING SERVICES DURING DESIGN PHASE FOR BAS PANEL PARTS AND PROGRAMMING. SEE WSU DESIGN STANDARD 25 50 00.